

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water

Sample Name: 135 Hook Road
Lab Code: R2501652-001

Service Request: R2501652
Date Collected: 02/18/25 07:51
Date Received: 02/18/25 12:22

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	8.4	0.50	1	02/25/25 16:22	
Bromoform	ND U	0.50	1	02/25/25 16:22	
Chloroform	22	0.50	1	02/25/25 16:22	
Dibromochloromethane	1.7	0.50	1	02/25/25 16:22	
Trihalomethanes, Total	33	2.0	1	02/25/25 16:22	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	105	70 - 130	02/25/25 16:22	
Bromofluorobenzene	84	70 - 130	02/25/25 16:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water
Sample Name: 357 County Rd 28
Lab Code: R2501652-002

Service Request: R2501652
Date Collected: 02/18/25 08:19
Date Received: 02/18/25 12:22

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	9.2	0.50	1	02/25/25 16:47	
Bromoform	ND U	0.50	1	02/25/25 16:47	
Chloroform	28	0.50	1	02/25/25 16:47	
Dibromochloromethane	2.0	0.50	1	02/25/25 16:47	
Trihalomethanes, Total	39	2.0	1	02/25/25 16:47	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	102	70 - 130	02/25/25 16:47	
Bromofluorobenzene	83	70 - 130	02/25/25 16:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water
Sample Name: 448 Sheldon Rd
Lab Code: R2501652-003

Service Request: R2501652
Date Collected: 02/18/25 08:36
Date Received: 02/18/25 12:22

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	8.1	0.50	1	02/25/25 17:12	
Bromoform	ND U	0.50	1	02/25/25 17:12	
Chloroform	22	0.50	1	02/25/25 17:12	
Dibromochloromethane	1.7	0.50	1	02/25/25 17:12	
Trihalomethanes, Total	32	2.0	1	02/25/25 17:12	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	101	70 - 130	02/25/25 17:12	
Bromofluorobenzene	79	70 - 130	02/25/25 17:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water
Sample Name: 5923 Loomis Rd
Lab Code: R2501652-004

Service Request: R2501652
Date Collected: 02/18/25 08:50
Date Received: 02/18/25 12:22

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	7.6	0.50	1	02/25/25 17:37	
Bromoform	ND U	0.50	1	02/25/25 17:37	
Chloroform	20	0.50	1	02/25/25 17:37	
Dibromochloromethane	1.6	0.50	1	02/25/25 17:37	
Trihalomethanes, Total	29	2.0	1	02/25/25 17:37	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	97	70 - 130	02/25/25 17:37	
Bromofluorobenzene	86	70 - 130	02/25/25 17:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water
Sample Name: 5150 North St
Lab Code: R2501652-005

Service Request: R2501652
Date Collected: 02/18/25 09:31
Date Received: 02/18/25 12:22

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	7.0	0.50	1	02/25/25 18:02	
Bromoform	ND U	0.50	1	02/25/25 18:02	
Chloroform	16	0.50	1	02/25/25 18:02	
Dibromochloromethane	1.5	0.50	1	02/25/25 18:02	
Trihalomethanes, Total	24	2.0	1	02/25/25 18:02	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	100	70 - 130	02/25/25 18:02	
Bromofluorobenzene	80	70 - 130	02/25/25 18:02	